

SPECIFICATIONS

SHIELDING REQUIREMENTS:

- BACK WALL 2" THK LEAD
- SIDE WALLS 3/4" THK LEAD
- ROOF 1/2" THK LEAD

CONSTRUCTION: MODULAR

STRUCTURE: SELF-SUPPORTED

- COMMERCIAL RATED: 40 LBS LIVE WEIGHT/SQ FT
- 100 LBS DEAD WEIGHT/SQ FT

OVERALL DIMS:

- 1.75M Avg WIDTH X 11.50M LONG X 3.3M HIGH [5.8' X 37.7' X 11']
- CLEAR HEIGHT INSIDE: 3M [10']
- DOOR OPENING: 2.4M HIGH X 1M WIDE [8' X 3.3']

SLIDING DOORS:

- TWO MANUAL, FIXED BY LATCH
- TWO PNEUMATIC WITH MANUAL OVERRIDE

STANDARD SIDE PANEL: 1M WIDE X 3.3M HIGH [3.3'X11']

- SANDWICH CONSTRUCTION:
- STEEL 3mm [1/8" (11Ga)] - LEAD 19mm [3/4"] - STEEL 6mm [1/4"]
- STRUCTURE: 3 1/2" X 3 1/2" X 1/4" STEEL ANGLE, ALL AROUND
- WEIGHT: 2280LB

STANDARD BACK PANEL: 1M WIDE X 3.3M HIGH [3.3'X11']

- SANDWICH CONSTRUCTION:
- STEEL 3mm [1/8" (11Ga)] - LEAD 50mm [2"] - STEEL 6mm [1/4"]
- STRUCTURE: 3 1/2" X 3 1/2" X 1/4" STEEL ANGLE, ALL AROUND
- WEIGHT: 5680LB

STANDARD ROOF PANEL: 1M WIDE X 1.75M LONG [3.3'X5.8']

- SANDWICH CONSTRUCTION:
- STEEL 3mm [1/8" (11Ga)] - LEAD 12mm [1/2"] - STEEL 6mm [1/4"]
- STRUCTURE: MC 6 X 16.3 STEEL CHANNEL, ALL AROUND
- WEIGHT: 1150LB

STANDARD DOOR PANEL: 1M WIDE X 2.5M HIGH [3.3'X8']

- SANDWICH CONSTRUCTION:
- STEEL 3mm [1/8" (11Ga)] - LEAD 19mm [3/4"] - STEEL 6mm [1/4"]
- WEIGHT: 1470LB

LABYRINTH PANELS: UTILITIES, CABLES, VENTILATION, OZONE

UTILITIES: CHILLED WATER 5°-0.8°C [4°-1.5°F]


- DI WATER
- COMPRESSED AIR 90psi
- ELECTRICAL POWER 30kVA 120/208V

WORK STATION CRANE WITH MANUAL HOIST:

- SPAN 1.14M [3.75'] X RUNWAY LENGTH 9.00M [29.53'] X CLEAR HEIGHT 3M [10']

CAPACITY: 1000Kg [1 TON]

ILLUMINATION: FLUORESCENT- OFFICE RATED: 100 FOOT CANDLE.



NOTES:

1- THE HUTCH MANUFACTURER SHALL BE RESPONSIBLE FOR THE STRUCTURAL INTEGRITY OF THE HUTCH, AND SHALL CERTIFY THAT THE STRUCTURE WAS REVIEWED BY A LICENSED STRUCTURAL ENGINEER.

STRUCTURES AND THEIR ELEMENTS SHALL BE BUILT FOLLOWING DOE 6430 AS REFERRED TO IN TECHNICAL SPECS. DESIGN LOADS SHALL INCLUDE LOADS THAT CAN OCCUR DURING CONSTRUCTION. DEAD LOADS SHALL INCLUDE THE USE OF THE INTERIOR UNISTRUT FOR SHELVES ONE FOOT WIDE SUPPORTING LOADS OF 200 LBS.

2- LEAD THICKNESS IS SPECIFIED BY ARGONNE. THE MANUFACTURER SHALL BE RESPONSIBLE FOR PROVIDING A RADIATION LEAK PROOF HUTCH.

LEAD LINED PANELS SHALL BE CONSTRUCTED FROM SINGLE UNPIERCED SHEET, FREE OF OXIDE INCLUSIONS, FISSURES, VOIDS AND ALL OTHER DETRIMENTAL DEFECTS. MATERIAL SHALL BE LEAD GRADE 'C' TO COMPLY WITH FEDERAL SPECIFICATION QQ-L-201. HUTCH SHALL MEET ALL APPLICABLE RADIATION GUIDE LINES REFERRED TO IN TECHNICAL SPECS.

02	TO COMPLETE ASSY DRAWINGS	IMP	TS	07/2008
01	UPDATED & REV SMT 2	ES	TS	07/2008

REV	DATE	BY	CHKD	DESCRIPTION	APP'D
01	4/20/08	T. TORRES	D. SHU	ISSUED FOR CONSTRUCTION	
02	4/20/08	T. TORRES	T. KUZAY	REVISED FOR CONSTRUCTION	
03	4/20/08	T. TORRES	D. MULLS	REVISED FOR CONSTRUCTION	
04	4/20/08	T. TORRES		REVISED FOR CONSTRUCTION	

ARGONNE NATIONAL LABORATORY
 THE ADVANCED PHOTON SOURCE
 H1 APS FOE 2-ID-A FIRST OPTICS ENCLOSURE ASSEMBLY
 PERSPECTIVE & SPECIFICATIONS
 SHEET 210 OF 210
 P41050903-430000-02